

Dry or Wet Chemical Fire Suppression System Permit Application Requirements

Fees: The fees listed are valid through December 31, 2017. The next fee adjustment will be effective January 1, 2018.

New System (& extensive changes to a system)	\$350
Minor Alterations to Existing System	\$266
Inspection/Testing, if over 2 hours	Hourly Rate

The following information is required to be submitted.

The shaded area indicates the minimum information required for permit application acceptance by the City of Woodinville Permit Center. Final approval of permit will require that all information, as applicable, be provided.

**3 sets of plans
and cut sheets are
required.**

- A complete application.
- 3 sets of manufacturer's literature, "cut sheets."
- 3 sets of floor plans
- Owner's name, address and phone number
- Contractor's name, address, phone number, and L. & I. License No.
- Systems must meet UL 300 Requirements (Per Ordinance #263)

The following information is required for final permit approval:

- Plans to include:
 - Compass direction and clearly marked scale
 - Full building plan
- System information:
 - Legend showing all symbols, device descriptions, size and type of pipe
 - All bracing and attachments shall be identified. If bracing will be attached to trusses or other lightweight members a letter from truss manufacturers shall be provided approving load carrying capacity of members.
- References cited for any exceptions or deviations being requested.